



2 TYPICAL CHILLED WATER COIL CONNECTION (FCU)
NO SCALE




3 TYPICAL HOT WATER COIL CONNECTION (FCU)
NO SCALE




NOTE:
INSTALL IN A LOCATION THAT PROVIDES SUFFICIENT CLEARANCE
TO VALVES AND CABINET FOR MAINTENANCE.

7 CLEAN ROOM HUMIDIFIER INSTALLATION
NO SCALE


SANITARY LINE







5 PENETRATION OF FIRE/SMOKE BARRIERS



RECESSED LIGHT FIXTURES

FULLY SPRINKLERED FOR CONSTRUCTION

							FOR CO	ONSTRUCTION
	KEY PLAN:	STAMP:	CONSULTANTS:	ARCHITECT/ENGINEERS:	Drawing Title MECHANICAL	Project Title RENOVATE INPATIENT	Project Number R636A8-10-001	Office of
		THE OF MAD TO THE		11000 West Park Place ▲ Milwaukee WI 53224 ▲ Tel 414 359-3060 ▲ Fax 414 359-3070	DETAILS	MEDICAL/SURGICAL WARD 7E	Building Number 1	Construction and Facilities
	N N		NIKA Technologies, Inc. 11400 Rockville Pike, Ste 505	Plunkett Raysich Intelligent Designs Inspired Results A rchitects www.prarch.com	Approved: Project Director	Location Iowa City VA Medical Center	Drawing Number	Management
Revisions: Date	7E////	PEGISTENED CHANGE	Engineering and Management N. Bethesda, MD 20852 Consultants p: 301.770.3520 f: 301.770.3521 www.nikatechnologies.com	www.prarch.com		Date Checked Drawn MS MS	1-H4 Dwg. 18 of 44	Department of Veterans Affairs
FORM 08-6231		J L						

3 4 5 7